



City of Reedley

Public Works Department
1733 Ninth Street
Reedley, CA 93654
(559) 637-4200 Ext. 214
FAX 637-2139

CITY OF REEDLEY WASTEWATER TREATMENT PLANT REQUEST FOR PROPOSAL (RFP) FOR INSTALLATION OF A GROUNDWATER WELL REMEDIATION PROJECT

The City of Reedley Public Works Department, Wastewater Division is issuing a Request for Proposals (RFP) to provide an existing Groundwater Monitoring Well with the necessary equipment and power source to initiate a groundwater remediation plan.

It is the City's preference that proposals be submitted for the entire scope of services described herein. All interested contractors or parties considering the submittal of a proposal for this project must register by **February 26, 2014** with Martha S. Cardoso via email at martha.cardoso@reedley.ca.gov. Please include the following: Company Name, Contact Name, Telephone Number, Address and email address.

In order that the City can provide accurate, clear and consistent response, please address any questions regarding the RFP no later than **March 3, 2014** via email to:

City of Reedley
Wastewater Treatment Plant
Martha S. Cardoso
(559) 637-4233
martha.cardoso@reedley.ca.gov

RFP Submittal Instructions

Please deliver your RFP by **4:00 p.m. on March 10, 2014** to the Public Works office located at: **1733 9th Street, Reedley, CA 93654**. Please indicate on the accompanying envelope or correspondence with the following:

Public Works-Groundwater Well Remediation Proposal.

It is the intent of the City to only consider those companies that participate in this process. Proposals, pricing or other offers received after this time and date may be rejected at the City's sole discretion. Notification of the awarded party will be sent out to all participants within 7-10 business days following the closing date of submittals.

Introduction

The City of Reedley Wastewater Treatment Plant under direct order of the State Regional Water Quality Control Board, Central San Joaquin Valley is to provide a

groundwater remediation plan on one existing groundwater monitoring well located near the wastewater treatment plant identified as Groundwater Monitoring Well #3 (MW-3). The remediation plan will consist of installing a permanent submersible pump in the well and ran until the desired remediation level is acquired.

MW-3 consists of a 4 inch Schedule 40 PVC casing forty feet (40') deep well. On February 9, 2012 the well was videoed and found to have a 20 foot horizontal factory slot perforating start; 24 foot static water level; and 40 feet to bottom of the well.

In June 10, 2002 the well pump test data was determined as follows:

| Monitoring Well | Pumping Rate (gpm) | Static Water Level (feet) | Pumping Water Level (feet) | Drawdown (feet) | Specific Capacity (gpm/ft) |
|-----------------|--------------------|---------------------------|----------------------------|-----------------|----------------------------|
| 3 | 6 | 24.0 | 28.3 | 4.3 | 1.4 |

Scope of Work

- Install a permanent submersible pump with a minimum pumping capability of 10 gpm that will meet the projects requirements with pump settings at 35 feet.
- Install an access tube (3/4 inch in diameter) near the pump intake.
- Install an on/off sensor on pump to safeguard when well pumped dry.
- Install a totalizing flow meter that reads in gallons.
- Install a drain line from the well to the manhole located near the well.
- Install a control valve in the discharge line next to the well along with a sample spigot.
- Arrange for power source (220/110v) to be provided by PG&E.
- Run electrical supply to well site and equipment.
- Start up pump and set field pump settings.
- Secure area with a chain link privacy fence with 3 strands of barbed wire with an access door surrounding the perimeter of the affected area.
- Place 4 inches of pebble rock within the fenced area after have graded and leveled area.
- May need to install a canopy to protect electrical components. To be determined at a later time. Recommend cost be included as an optional item.
- Include any other options and accessories that may be offered or needed that may have been overlooked by this scope of work. These extras will be shared with other interested parties, so they may have an opportunity to include in final pricing, as well.

Statement of Qualifications

- A description of the proposed contractor, including qualifications, experience and organizational information.

insurance shall include the coverage for the owned, hired and non-owned automobiles.

The Certificates of Insurance shall have as a minimum the following: 1. Name of the City of Reedley, its officers, officials, agents, employees and volunteers, as additional insured.; 2. State that such policy shall be endorsed so Contractor's Insurance shall be primary and no contribution shall be required of the City. Coverage cannot be suspended, voided, cancelled, reduced in coverage or otherwise materially changed until the completion of the project.

Miscellaneous Provisions

- All work performed under this contract is subject to prevailing wage laws.
- Please stipulate how soon after awarding the proposal will the installation process begin and expected duration to complete the project.