



ADDENDUM

Community Development Dept.
Engineering Division
1733 Ninth Street, Reedley, CA 93654
(559)637-4200, Ext. 295
Fax: (559)637-2139

City of Reedley
Community Development Department

**ADDENDUM NO. 2
TO THE SPECIFICATIONS FOR
CITY OF REEDLEY
Luke Trimble Park Rehabilitation**


**Bid Date:
March 29, 2018**

The following additions and/or corrections shall become part of the Contract Documents and Construction Specifications for the subject project.

Notice to all Contractors submitting bids for this work and to all contract document holders.

You are hereby notified of the following changes to the Contract Documents, more specifically, to the Bid Proposal Package and the construction plans for this project. This addendum shall supersede the original contract documents wherein it contradicts the same and shall take precedence over anything to the contrary therein. All conditions remain the same.

Approved by:



City Engineer

RCE

03/26/2018

Date

NOTICE: This Addendum shall be acknowledged by the Contractor submitting the bid in the space provided below and this addendum shall be submitted with the Contractor's Bid Proposal as well as faxed for acknowledgement of receipt to the City of Reedley. Failure to acknowledge may result in the proposal being rejected as not responsive.

**Sign and fax this sheet to
559-637-2139**

Contractor: _____

Contractor's Signature

Date

Item No.	Reference	Description of Change
Bid and Contract Documents		
1.	RFI #1	Buy America does not apply to this project.
Project Special Provisions		
1.	RFI #2	Written specifications for the fence/gates were not included. Please use details and information included in RFI responses.
2.	RFI #3	Water supply will be from bathroom. No additional concrete work will be needed.
3.	RFI #4	Please recommend an outdoor latch to be approved by owner. City of Reedley to provide lock.
4.	RFI #5	Please replace paragraph 2 of Section 10-2.10 with the following: <i>Full compensation for all costs involved in the construction and installation of the new wrought iron fence with mowstrip shall be included in the unit price bid, per lineal foot, and no additional payment will be made therefor.</i>
5.	RFI #5	Please replace paragraph 2 of Section 10-2.11 with the following: <i>Full compensation for all costs involved in the construction and installation of the new wrought iron gate shall be included in the unit price bid, per lineal foot, and no additional payment will be made therefor.</i>
6.	RFI #6	Fence panels can be welded or mounted with brackets. Contractor's choice. Black powder coat for the fence. 16 gauge for panels is acceptable.
7.		Please add the following to Section 10-2.02 : <i>City will allow roadway reconstruction work in both Reed Avenue and 8th Avenue to be performed, simultaneously, with appropriate traffic control. Both streets must be open to 2-way traffic at the end of each workday, and over weekends and holidays during the construction period. City will allow temporary closure of the alley between 8th Avenue and Reed Avenue during working days, with posted and circulated 48 hour notice to residents in apartments to north of project. Closure shall be limited to working days between 8 am and 4 pm.</i>

Plan Sheets		
1.	WP-4	Note 3: Substitute National Brand filter with (2) Pentair Triton TR100C filters with 261055 2" multi port valves each.